



CERTIFICATE

No. Z2 083334 0056 Rev. 01

Holder of Certificate:

Ningbo Ulica Solar

Science & Technology Co., Ltd

No. 181, Shanshan Road Wangchun Industrial District

315177 Ningbo

PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.:

704061909505-01

Valid until:

2024-10-09

Date,

2019-10-10

(Zhulin Zhang)



Sub



CERTIFICATE

No. Z2 083334 0056 Rev. 01

Model(s):

1000 V DC system voltage Single Glass modules:

UL-xxxM-72, xxx= 330 to 390 in step of 5; UL-xxxM-60, xxx= 275 to 325 in step of 5; UL-xxxM-54, xxx= 245 to 290 in step of 5;

1500 V DC system voltage Single Glass modules: UL-xxxM-72HV, xxx= 330 to 390 in step of 5; UL-xxxM-60HV, xxx= 275 to 325 in step of 5; UL-xxxM-54HV, xxx= 245 to 290 in step of 5; xxx is standing for rated output power at STC

Parameters:

Construction:

Framed, with Junction box, Cable and Connectors.

Safety Class:

Class II

Maximum System Voltage:

1500 V DC or 1000 V DC Class C according to UL 790

Fire Safety Class:

Tested according to:

IEC 61215-1(ed.1) IEC 61215-1-1(ed.1) IEC 61215-2(ed.1) IEC 61730-1(ed.2) IEC 61730-2(ed.2) IEC 62716(ed.1)

Production Facility(ies): 083334

